



Wayne-Westland Community Schools
 Drinking Water Analysis
 Project Number: AE16005

Hamilton Elementary School						
Date of Sampling: October 12, 2016						
Sampler: Brad Ziegler						
Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Notes
HA-01	Kitchen Prep West	KS	6:01 AM	15	ND ³	First Draw
HA-02	Room 23	B	6:05 AM	15	3	First Draw
HA-03	Room 18	B	6:09 AM	15	1	First Draw
HA-04	Room 17	CF	6:11 AM	15	ND	First Draw
HA-05	Room 14	CF	6:19 AM	15	ND	First Draw
HA-06	Room 14	B	6:21 AM	15	ND	First Draw
HA-07	Room 9	B	6:25 AM	15	2	First Draw
HA-08	Room 6	CF	6:32 AM	15	3	First Draw
HA-09	Room 1	B	6:41 AM	15	ND	First Draw
HA-10	Room 1	CF	6:43 AM	15	10	First Draw
HA-11	Room 4	CF	6:47 AM	15	ND	First Draw
HA-12	Clinic	CF	6:50 AM	15	2	First Draw
HA-13	Office Mail Room	CF	6:55 AM	15	21	First Draw
HA-14	North Bubbler near Special Services	B	6:59 AM	15	1	First Draw
HA-15	Staff Lounge	CF	7:02 AM	15	1	First Draw

1) Type: B = Bubbler, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/to-be-regulated-drinking-water-contaminants>
 3) http://www.in.gov/iden/files/lead_epa_lead_copper_guide.pdf
 4) ND= Non Detected at Reported Detection Limit of 1 ug/L.
 5) NT = Not Tested