



Wayne-Westland Community Schools  
 Drinking Water Analysis  
 Project Number: AE170005

Adams Upper Elementary School							
Date of Sampling: March 14, 2017							
Sampler: Amanda Peterson							
Sample #	Location	Type <sup>1</sup>	Time Collected	EPA Action Level (ug/L) <sup>2</sup>	Results (ug/L)	Aerator Present Y/N	Notes
AM-01	Next to Room 281-outside of door 111 (storage) to the right	B	5:58 AM	15	1	N	First Draw
AM-02	To the left of door 107 (electrical room)	B	6:05 AM	15	2	N	First Draw
AM-03	In cafeteria, to the right of door 305a.	WC	6:18 AM	15	ND <sup>3</sup>	N	First Draw
AM-04	To the right of door 406, across from room 405.	B	6:31 AM	15	2	N	First Draw
AM-05	North gym (403)- left bubbler	B	6:36 AM	15	ND	N	First Draw
AM-06	To the right of classroom 251	B	6:40 AM	15	2	N	First Draw
AM-07	Across from room 330- left bubbler	B	6:52 AM	15	3	N	First Draw
AM-08	Across from room 330- right bubbler	B	6:53 AM	15	ND	N	First Draw
AM-09	To the left of room 313, right of health clinic, left bubbler	B	6:58 AM	15	1	N	First Draw
AM-10	To the left of room 313, right of health clinic, right bubbler	B	6:59 AM	15	2	N	First Draw
AM-11	Main Office, across from door 100e.	KS	7:13 AM	15	ND	N	First Draw
AM-12	Staff Lounge	KS	7:15 AM	15	ND	N	First Draw
AM-13	Left of room 261, right of electrical room	B	7:20 AM	15	ND	N	First Draw
AM-14	White gym-left bubbler	B	7:28 AM	15	ND	N	First Draw
AM-15	White gym-right bubbler	B	7:29 AM	15	ND	N	First Draw

1) Type: B = Bubbler; WC = Water Cooler; CF = Classroom Faucet; KS = Kitchen Sink; NS = Nurse Sink; S = Sink Used for Drinking  
 2) <http://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non-Detect at Report Detection Limit of 1 ug/L