



Wayne-Westland Community Schools
 Drinking Water Analysis
 Project Number: AE170005

Edison Elementary School							
Date of Sampling: April 4, 2017							
Sampler: Jessica Perfetti							
Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
ED-01	Upper elementary wing, far left of Room 20, water cooler	WC	6:07 AM	15	ND ³	N/A	First Draw
ED-02	Room 15 bubbler	B	6:13 AM	15	ND	N/A	First Draw
ED-03	Room 15 classroom faucet	CF	6:13 AM	15	ND	Y	First Draw
ED-04	Room 21 bubbler	B	6:18 AM	15	ND	N/A	First Draw
ED-05	Room 21 classroom faucet	CF	6:18 AM	15	ND	Y	First Draw
ED-06	Room 22 bubbler	B	6:23 AM	15	1	N/A	First Draw
ED-07	Room 22 classroom faucet	CF	6:23 AM	15	1	Y	First Draw
ED-08	Room 14 bubbler	B	6:28 AM	15	ND	N/A	First Draw
ED-09	Room 14 classroom faucet	CF	6:28 AM	15	ND	Y	First Draw
ED-10	Room 13 bubbler	B	6:32 AM	15	ND	N/A	First Draw
ED-11	Room 13 classroom faucet	CF	6:32 AM	15	2	Y	First Draw
ED-12	Room 23 bubbler	B	6:37 AM	15	ND	N/A	First Draw
ED-13	Room 23 classroom faucet	CF	6:37 AM	15	ND	Y	First Draw
ED-14	Kitchen, left faucet, 3-compartment sink	KS	6:43 AM	15	6	Y	First Draw
ED-15	Kitchen, right faucet, 3-compartment sink	KS	6:43 AM	15	8	Y	First Draw

1) Type: B = Bubbler, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested