



Wayne Westland Community Schools
 Drinking Water Analysis
 Project Number: AE16005

Hoover Elementary School						
Date of Sampling: October 13, 2016						
Sampler: Kalan Briggs						
Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Notes
HO-01	Art Room	B	6:01 AM	15	3	First Draw
HO-02	Room 117, Kindergarten	B	6:07 AM	15	ND ³	First Draw
HO-03	Next to room 103, left side	B	6:11 AM	15	8	First Draw
HO-04	Staff Lounge	KS	6:15 AM	15	ND	First Draw
HO-05	Room 100	B	6:20 AM	15	ND	First Draw
HO-06	Room 103	B	6:25 AM	15	1	First Draw
HO-07	Room 105	B	6:28 AM	15	4	First Draw
HO-08	Room 108	B	6:32 AM	15	2	First Draw
HO-09	Room 106	B	6:36 AM	15	ND	First Draw
HO-10	Room 104	B	6:41 AM	15	ND	First Draw
HO-11	Room 108	B	6:45 AM	15	10	First Draw
HO-12	Room 113	B	6:50 AM	15	3	First Draw
HO-13	Clinic	KS	6:55 AM	15	2	First Draw
HO-14	Room 114	CF	7:00 AM	15	4	First Draw
HO-15	Kitchen 3 compartment Sink, right side	KS	7:05 AM	15	2	First Draw

1) Type: B = Bubbler, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <http://www.epa.gov/your-drinking-water/to-be-regulated-drinking-water-contaminants>
 3) http://www.in.gov/idem/files/lead_epa_lead_copper_guide.pdf
 4) ND= Non Detected at Reported Detection Limit of 1 ug/L
 5) NT = Not Tested